



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Paul Maziarz
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150**

1/6/2017

Phone: (716) 821-7440
Fax: (716) 821-7037

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/10/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 1700795 NY State Component School Dist.
FLETCHER ELEMENTARY RETEST**

The reference number for these samples is EMSL Order #011607660. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607660
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: FLETCHER ELEMENTARY RETEST

Analytical Results

Client Sample Description FE10-RM 103 **Collected:** 10/31/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.2	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE14-RM 105 BATHROOM LAV **Collected:** 10/31/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	18.0	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE17-RM 107 NURSE BATH LAV **Collected:** 10/31/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.55	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE22-BOYS LOCKER RM SINK A **Collected:** 10/31/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.65	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE23-BOYS LOCKER RM SINK B **Collected:** 10/31/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.72	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE24-GIRLS LOCKER RM SINK A **Collected:** 10/31/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.57	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE25-GIRLS LOCKER RM SINK A **Collected:** 10/31/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.93	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607660
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: FLETCHER ELEMENTARY RETEST

Analytical Results

Client Sample Description FE37-RM 204 **Collected:** 10/31/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.4	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE42-RM 205 **Collected:** 10/31/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.9	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Client Sample Description FE57-MAIN OFFICE BATHROOM SINK **Collected:** 10/31/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.8	1.00	µg/L	12/27/2016	CB	1/3/2017	BB

Client Sample Description FE-27-GIRLS BATHROOM SINK A **Collected:** 10/31/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.61	1.00	µg/L	12/27/2016	CB	12/28/2016	BB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)