



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Paul Maziarz  
Tonawanda City School District  
100 Hines Street  
Tonawanda, NY 14150**

10/18/2016

Phone: (716) 821-7440  
Fax: (716) 821-7037

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/7/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 1700795 NY State Component School Dist.  
Mullen Elementary**

The reference number for these samples is EMSL Order #011606632. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

<i>Client Sample Description</i>				<i>Collected:</i>		<i>Lab ID:</i>		
ME1 Source				9/24/2016		0001		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	359	20.0	µg/L	10/14/2016	JS	10/15/2016	EG
ME2 Kitchen - Faucet Sink				9/24/2016		0002		
200.8	Lead	1.97	1.00	µg/L	10/14/2016	JS	10/15/2016	EG
ME3 Kitchen A - Pot Filler				9/24/2016		0003		
200.8	Lead	1.75	1.00	µg/L	10/14/2016	JS	10/15/2016	EG
ME4 Kitchen B - Pot Filler				9/24/2016		0004		
200.8	Lead	1.05	1.00	µg/L	10/14/2016	JS	10/15/2016	EG
ME5 Kitchen C - Pot Filler				9/24/2016		0005		
200.8	Lead	4.06	1.00	µg/L	10/14/2016	JS	10/15/2016	EG
ME6 Cafeteria				9/24/2016		0006		
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	EG
ME7 Cafeteria Entrance Bubler				9/24/2016		0007		
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME8  
 Cafeteria Entrance Boys Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.3	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME9  
 Cafeteria Entrance Girls Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.4	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME10  
 Rm 101  
**Collected:** 9/24/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.02	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME11  
 Rm 102  
**Collected:** 9/24/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.91	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME12  
 Rm 103  
**Collected:** 9/24/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.09	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME13  
 Rm 103 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.84	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME14  
 Rm 104  
**Collected:** 9/24/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME15  
Rm 104 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME16  
Rm 105  
**Collected:** 9/24/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.87	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME17  
Rm 105 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.61	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME18  
Rm 108 Mrs. Kuun  
**Collected:** 9/24/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.99	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME19  
Rm 107  
**Collected:** 9/24/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.40	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME20  
Rm 107 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.46	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME21  
Nurse  
**Collected:** 9/24/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME22  
Nurse Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.6	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME23  
Principal's Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.25	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME24  
Rm 109  
**Collected:** 9/24/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.2	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME25  
Rm 109 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.29	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME26  
OT/PT Bathroom Boys  
**Collected:** 9/24/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.97	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME27  
OT/PT Bathroom Girls  
**Collected:** 9/24/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.66	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME28  
Boiler Room  
**Collected:** 9/24/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.8	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME29  
Boiler Room Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME30  
Girls Locker Room A  
**Collected:** 9/24/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.08	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME31  
Girls Locker Room B  
**Collected:** 9/24/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.12	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME32  
Boys Locker Room A  
**Collected:** 9/24/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.67	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME33  
Boys Locker Room B  
**Collected:** 9/24/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.38	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME34  
Main Entrance Corridor Bubbler  
**Collected:** 9/24/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.27	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME35  
Main Entrance Corridor Womens Bathroom  
Sink A  
**Collected:** 9/24/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.5	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME36  
 Main Entrance Corridor Womens Bathroom  
 Sink B  
**Collected:** 9/24/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.12	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME37  
 Main Entrance Corridor Mens Bathroom  
 Sink A  
**Collected:** 9/24/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.88	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME38  
 Main Entrance Corridor Mens Bathroom  
 Sink B  
**Collected:** 9/24/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.8	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME39  
 Rm 138  
**Collected:** 9/24/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME40  
 Rm 112  
**Collected:** 9/24/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.0	1.00	µg/L	10/14/2016	JS	10/15/2016	EG

**Client Sample Description** ME41  
 Rm 113  
**Collected:** 9/24/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.8	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME42  
 Rm 114  
**Collected:** 9/24/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.9	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME43  
 Corridor Bubbler near Gang Bathrooms  
**Collected:** 9/24/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME44  
 Corridor Girls Bathroom Sink A  
**Collected:** 9/24/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.16	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME45  
 Corridor Girls Bathroom Sink B  
**Collected:** 9/24/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.95	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME46  
 Corridor Girls Bathroom Sink C  
**Collected:** 9/24/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.97	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME47  
 Corridor Boys Bathroom Sink A  
**Collected:** 9/24/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.11	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME48  
 Corridor Boys Bathroom Sink B  
**Collected:** 9/24/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.93	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME49  
 Corridor Boys Bathroom Sink C  
**Collected:** 9/24/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.10	1.00	µg/L	10/14/2016	JS	10/15/2016	JS



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME50  
Rm 115  
**Collected:** 9/24/2016  
**Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.4	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME51  
Rm 116  
**Collected:** 9/24/2016  
**Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.1	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME53  
Rm 118  
**Collected:** 9/24/2016  
**Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME54  
Rm 118 Bathroom  
**Collected:** 9/24/2016  
**Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.3	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME55  
Rm 120  
**Collected:** 9/24/2016  
**Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME56  
Rm 120 Bathroom  
**Collected:** 9/24/2016  
**Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.5	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME57  
Rm 121  
**Collected:** 9/24/2016  
**Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.29	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME58  
Rm 121 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.3	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME59  
Rm 122  
**Collected:** 9/24/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME60  
Rm 122 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	25.8	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME61  
Rm 123  
**Collected:** 9/24/2016 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/14/2016	JS	10/15/2016	JS

**Client Sample Description** ME62  
Rm 123 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	23.9	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME63  
Rm 124  
**Collected:** 9/24/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME64  
Rm 124 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	011606632
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**  
**Tonawanda City School District**  
**100 Hines Street**  
**Tonawanda, NY 14150**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 10/07/16 9:30 AM

Project: **Mullen Elementary****Analytical Results**

**Client Sample Description** ME65  
Rm 125  
**Collected:** 9/24/2016  
**Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME66  
Rm 125 Bathroom  
**Collected:** 9/24/2016  
**Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.6	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME67  
Rm 126  
**Collected:** 9/24/2016  
**Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME68  
Rm 126 Bathroom  
**Collected:** 9/24/2016  
**Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.7	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Client Sample Description** ME69  
Rm 102 Bubbler  
**Collected:** 9/24/2016  
**Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.41	1.00	µg/L	10/13/2016	JS	10/15/2016	EG

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)