



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Paul Maziarz
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150**

1/6/2017

Phone: (716) 821-7440
Fax: (716) 821-7037

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/10/2016. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 1700795 NY State Component School Dist.
TONAWANDA MS/HS**

The reference number for these samples is EMSL Order #011607666. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607666
 CustomerID: TWCS25
 CustomerPO: 1700795
 ProjectID: PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH1-WATER MAIN **Collected:** 10/29/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH2 -HS GIRLS LOCKER ROOM **Collected:** 10/29/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH3-HS GIRLS LOCKER ROOM A **Collected:** 10/29/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.47	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH4- HS GIRLS LOCKER ROOM B **Collected:** 10/29/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH5-HS GIRLS LOCKER ROOM OFFICE **Collected:** 10/29/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.75	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH6-RM 319 **Collected:** 10/29/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.4	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH7-RM 319 **Collected:** 10/29/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.5	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH8-HS NURSE OFFICE LAV **Collected:** 10/29/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH9-HS NURSE OFFICE **Collected:** 10/29/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.47	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH10-HS FITNESS - A **Collected:** 10/29/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH11-HS FITNESS - B **Collected:** 10/29/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH12-HS FITNESS - C **Collected:** 10/29/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH13-HS FITNESS - D **Collected:** 10/29/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH14-HS ART COR GIRLS A **Collected:** 10/29/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH15-HS ART COR GIRLS B **Collected:** 10/29/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH16-HS ART COR GIRLS C **Collected:** 10/29/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH17-HS ART COR BOYS C **Collected:** 10/29/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH18-HS 156-A **Collected:** 10/29/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH19-HS 156-B **Collected:** 10/29/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH20-HS 156-C **Collected:** 10/29/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.11	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH21-HS 156-D **Collected:** 10/29/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.89	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH22-HS 158-A **Collected:** 10/29/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH23-HS 158-B **Collected:** 10/29/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH24-HS 158-C **Collected:** 10/29/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.20	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH25-HS 158-D **Collected:** 10/29/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.16	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH26-HS 158-E **Collected:** 10/29/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.64	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH27-HS 158-F **Collected:** 10/29/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.09	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH28-HS 158-G **Collected:** 10/29/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.57	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH29-HS 158-H **Collected:** 10/29/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.2	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH30-HS 158-I **Collected:** 10/29/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.38	1.00	µg/L	12/27/2016	CB	1/4/2017	EG

Client Sample Description MH31-HS 160-A **Collected:** 10/29/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.28	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH32-HS 160-B **Collected:** 10/29/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH33-HS 160-C **Collected:** 10/29/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH34-HS 160-D **Collected:** 10/29/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.62	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH35-HS 160-E **Collected:** 10/29/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.9	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 011607666
 CustomerID: TWCS25
 CustomerPO: 1700795
 ProjectID: PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH36-HS 160-F **Collected:** 10/29/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH37-HS 160-G **Collected:** 10/29/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.20	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH38-HS TEAM GIRLS LOCKER RM -A **Collected:** 10/29/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.68	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH39-HS TEAM GIRLS LOCKER RM B **Collected:** 10/29/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH40-HS TEAM LOCKER RM GIRLS **Collected:** 10/29/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.5	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH41-HS TEAM LOCKER RM OFFICE **Collected:** 10/29/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	48.6	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH42-HS SWIM POOL **Collected:** 10/29/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH43-HS MENS PUBLIC LAV A **Collected:** 10/29/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH44-HS MENS PUBLIC LAV B **Collected:** 10/29/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH45-HS MENS PUBLIC LAV C **Collected:** 10/29/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH46-HS LADIES PUBLIC LAV A **Collected:** 10/29/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH47-HS LADIES PUBLIC LAV B **Collected:** 10/29/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH48-HS LADIES PUBLIC LAV C **Collected:** 10/29/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH49-MS GIRLS LOCKER RM A **Collected:** 10/29/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH50-MS GIRLS LOCKER RM B **Collected:** 10/29/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.90	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH51-MS GIRLS LOCKER RM C **Collected:** 10/29/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.30	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH52-HS BOYS LOCKER RM **Collected:** 10/29/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH53-HS BOYS LOCKER RM OFFICE **Collected:** 10/29/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.80	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH54-HS BOYS LOCKER RM A **Collected:** 10/29/2016 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.5	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH55-HS BOYS LOCKER RM B **Collected:** 10/29/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.23	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH56-MS BOYS LOCKER RM A **Collected:** 10/29/2016 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.88	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH57-MS BOYS LOCKER RM B **Collected:** 10/29/2016 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.65	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH58-MS BOYS LOCKER RM C **Collected:** 10/29/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.4	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH59-MS/HS SUSPENSION **Collected:** 10/29/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.00	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH60-HS TEAM BOYS LOCKER RM A **Collected:** 10/29/2016 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.97	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH61-HS TEAM BOYS LOCKER RM B **Collected:** 10/29/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.14	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH62-HS TEAM BOYS LOCKER RM OFFICE **Collected:** 10/29/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.96	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH63-HS TEAM BOYS LOCKER RM **Collected:** 10/29/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.53	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH64-HS BAND RM **Collected:** 10/29/2016 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.98	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH65-HS DRESSING RM -BOYS **Collected:** 10/29/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.56	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH66-HS DRESSING RM -GIRLS **Collected:** 10/29/2016 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	18.8	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH67-HS AUD HALLWAY A **Collected:** 10/29/2016 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH68-HS AUD HALLWAY B **Collected:** 10/29/2016 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH69-HS MENS LAVATORY **Collected:** 10/29/2016 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.94	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH70-HS CLEANERS **Collected:** 10/29/2016 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.31	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH71-HS CUSTODIAN **Collected:** 10/29/2016 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.55	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH72-HS CUSTODIAN **Collected:** 10/29/2016 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.24	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH73-HS KITCHEN **Collected:** 10/29/2016 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH74-HS KITCHEN PREP **Collected:** 10/29/2016 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH75-HS KITCHEN -1 **Collected:** 10/29/2016 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH76-HS KITCHEN -2 **Collected:** 10/29/2016 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.44	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH77-HS KITCHEN -3 **Collected:** 10/29/2016 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.70	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH78-HS KITCHEN -4 **Collected:** 10/29/2016 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH79-HS KITCHEN -5 **Collected:** 10/29/2016 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH80-HS KITCHEN -6 **Collected:** 10/29/2016 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.38	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH81-HS KITCHEN -7 **Collected:** 10/29/2016 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH82-HS KITCHEN -8 **Collected:** 10/29/2016 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.52	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH83-MS KITCHEN-1 **Collected:** 10/29/2016 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH84-MS KITCHEN-2 **Collected:** 10/29/2016 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.20	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH85-MS KITCHEN-3 **Collected:** 10/29/2016 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.57	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH86-MS KITCHEN-4 **Collected:** 10/29/2016 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.32	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH87-MS KITCHEN-5 **Collected:** 10/29/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH88-MS KITCHEN-6 **Collected:** 10/29/2016 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.37	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH89-MS KITCHEN-7 **Collected:** 10/29/2016 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.54	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH90-MS KITCHEN-8 **Collected:** 10/29/2016 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH91-MS CAFE **Collected:** 10/29/2016 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH92-MS CAFE HALLWAY **Collected:** 10/29/2016 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.04	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH93-MS BOYS LAV A **Collected:** 10/29/2016 **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.69	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH94-MS BOYS LAV B **Collected:** 10/29/2016 **Lab ID:** 0094

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.44	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH95-MS BOYS LAV C **Collected:** 10/29/2016 **Lab ID:** 0095

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.71	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH96-MS GIRLS LAV A **Collected:** 10/29/2016 **Lab ID:** 0096

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.59	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH97-MS GIRLS LAV B **Collected:** 10/29/2016 **Lab ID:** 0097

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.32	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH98-MS GIRLS LAV C **Collected:** 10/29/2016 **Lab ID:** 0098

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.4	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH99-MS GIRLS LAV D **Collected:** 10/29/2016 **Lab ID:** 0099

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH100-MS HALLWAY 1ST FL **Collected:** 10/29/2016 **Lab ID:** 0100

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.82	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH101-MS LMC OFFICE **Collected:** 10/29/2016 **Lab ID:** 0101

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.96	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH102-MS RM 135 **Collected:** 10/29/2016 **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH103-MS HOME CARRER-A **Collected:** 10/29/2016 **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.52	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH104-MS HOME CARRER-B **Collected:** 10/29/2016 **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.35	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH105-MS HOME CARRER-C **Collected:** 10/29/2016 **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.00	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH106-MS HOME CARRER-D **Collected:** 10/29/2016 **Lab ID:** 0106

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.70	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH107-MS HINDS HALLWAY **Collected:** 10/29/2016 **Lab ID:** 0107

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.28	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH108-MS HOME CARRERR -EA **Collected:** 10/29/2016 **Lab ID:** 0108

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.58	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH109-MS 145 **Collected:** 10/29/2016 **Lab ID:** 0109

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.46	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH110-MS 147 **Collected:** 10/29/2016 **Lab ID:** 0110

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.91	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH111-HS LADIES LAV A **Collected:** 10/29/2016 **Lab ID:** 0111

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH112-HS LADIES LAV B **Collected:** 10/29/2016 **Lab ID:** 0112

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.35	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH113-HS MENS LAV **Collected:** 10/29/2016 **Lab ID:** 0113

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.38	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH114-HS RM 106 A **Collected:** 10/29/2016 **Lab ID:** 0114

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH115-HS RM 106 B **Collected:** 10/29/2016 **Lab ID:** 0115

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH116-HS BOYS LAV 1ST FL A **Collected:** 10/29/2016 **Lab ID:** 0116

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH117-HS BOYS LAV 1ST FL B **Collected:** 10/29/2016 **Lab ID:** 0117

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.71	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH118-HS BOYS LAV 1ST FL C **Collected:** 10/29/2016 **Lab ID:** 0118

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.51	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH119-HS HINDS COR -1 **Collected:** 10/29/2016 **Lab ID:** 0119

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH120-HS GIRLS LAV A **Collected:** 10/29/2016 **Lab ID:** 0120

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH121-HS GIRLS LAV B **Collected:** 10/29/2016 **Lab ID:** 0121

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.64	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH122-HS GIRLS LAV C **Collected:** 10/29/2016 **Lab ID:** 0122

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.26	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH123-HS GIRLS LAV D **Collected:** 10/29/2016 **Lab ID:** 0123

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.32	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH124-HS GIRLS LAV E **Collected:** 10/29/2016 **Lab ID:** 0124

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.9	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH125-BOARD OFFICE MENS LAV **Collected:** 10/29/2016 **Lab ID:** 0125

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.53	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH126-BOARD OFFICE MENS LAV **Collected:** 10/29/2016 **Lab ID:** 0126

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.3	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH127-BOARD OFFICE MENS LAV **Collected:** 10/29/2016 **Lab ID:** 0127

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.0	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH128-BOARD OFFICE MENS LAV **Collected:** 10/29/2016 **Lab ID:** 0128

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.09	1.00	µg/L	12/27/2016	CB	1/4/2017	BB

Client Sample Description MH129-HS HINDS COR-B **Collected:** 10/29/2016 **Lab ID:** 0129

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.00	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH130-BOARD OFFICE WOMENS LAV A **Collected:** 10/29/2016 **Lab ID:** 0130

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.03	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH131-BOARD OFFICE WOMENS LAV B **Collected:** 10/29/2016 **Lab ID:** 0131

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.65	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH132-BOARD OFFICE WOMENS LAV C **Collected:** 10/29/2016 **Lab ID:** 0132

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH133-BOARD OFFICE WOMENS LAV D **Collected:** 10/29/2016 **Lab ID:** 0133

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.44	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH134-HS BOARD OFFICE KITCHEN **Collected:** 10/29/2016 **Lab ID:** 0134

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.51	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH135-HS 108 **Collected:** 10/29/2016 **Lab ID:** 0135

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.50	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH136-HS 150 **Collected:** 10/29/2016 **Lab ID:** 0136

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.22	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH137-MS SCIENCE WING **Collected:** 10/29/2016 **Lab ID:** 0137

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.17	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH138-MS FLETCHER WING **Collected:** 10/29/2016 **Lab ID:** 0138

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.82	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH139-MS BOYS LAV 2A **Collected:** 10/29/2016 **Lab ID:** 0139

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH140-MS BOYS LAV 2B **Collected:** 10/29/2016 **Lab ID:** 0140

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607666

CustomerID: TWCS25

CustomerPO: 1700795

ProjectID: PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH141-MS GIRLS LAV 2A **Collected:** 10/29/2016 **Lab ID:** 0141

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH142-MS GIRLS LAV 2B **Collected:** 10/29/2016 **Lab ID:** 0142

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.47	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH143-MS GIRLS LAV 2C **Collected:** 10/29/2016 **Lab ID:** 0143

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH144-MS GIRLS LAV 2D **Collected:** 10/29/2016 **Lab ID:** 0144

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.3	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH145-FACULTY RM **Collected:** 10/29/2016 **Lab ID:** 0145

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.75	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH146-MS HIND CORR 2A **Collected:** 10/29/2016 **Lab ID:** 0146

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.53	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH147-HS LMC OFFICE **Collected:** 10/29/2016 **Lab ID:** 0147

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH148-HS BOYS LAV 2A **Collected:** 10/29/2016 **Lab ID:** 0148

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.14	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH149-HS BOYS LAV 2A **Collected:** 10/29/2016 **Lab ID:** 0149

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.64	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH150-HS HINDS CORR 2B **Collected:** 10/29/2016 **Lab ID:** 0150

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH151-HS GIRLS LAV 2A **Collected:** 10/29/2016 **Lab ID:** 0151

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.78	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH152-HS GIRLS LAV 2B **Collected:** 10/29/2016 **Lab ID:** 0152

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.27	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH153-HS GIRLS LAV 2C **Collected:** 10/29/2016 **Lab ID:** 0153

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.73	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH154-HS GIRLS LAV 2D **Collected:** 10/29/2016 **Lab ID:** 0154

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.90	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH155-HS GIRLS LAV 2E **Collected:** 10/29/2016 **Lab ID:** 0155

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.46	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH156-BOILER RM LAV **Collected:** 10/29/2016 **Lab ID:** 0156

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.4	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH157-BOILER RM LAUNDRY **Collected:** 10/29/2016 **Lab ID:** 0157

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.36	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH158-BASEMENT WOMENS LAV **Collected:** 10/29/2016 **Lab ID:** 0158

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH159-MS KITCHEN 1B **Collected:** 10/29/2016 **Lab ID:** 0159

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH160-MS KITCHEN **Collected:** 10/29/2016 **Lab ID:** 0160

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH161-HS KETTLE A **Collected:** 10/29/2016 **Lab ID:** 0161

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011607666
CustomerID:	TWCS25
CustomerPO:	1700795
ProjectID:	PO Box 1700795 N

Attn: **Paul Maziarz**
Tonawanda City School District
100 Hines Street
Tonawanda, NY 14150

Phone: (716) 821-7440
 Fax: (716) 821-7037
 Received: 11/10/16 9:30 AM

Project: TONAWANDA MS/HS

Analytical Results

Client Sample Description MH162-HS KETTLE A **Collected:** 10/29/2016 **Lab ID:** 0162

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH163-HS MAIN ENT **Collected:** 10/29/2016 **Lab ID:** 0163

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.93	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH164-MS HOME CARREER E **Collected:** 10/29/2016 **Lab ID:** 0164

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.96	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Client Sample Description MH165- MS HOME CARRER RM 145 **Collected:** 10/29/2016 **Lab ID:** 0165

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.49	1.00	µg/L	12/27/2016	CB	12/28/2016	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)